



8550 West Bryn Mawr Avenue
Suite #500
Chicago, Illinois 60631
Telephone 773-695-3500
Facsimile 773-695-3501

June 23, 2017

To: **All Bidders**

Re: **Oswego Police Department Headquarters**
Oswego, IL

BP #	DESCRIPTION	BP #	DESCRIPTION
28A	Security Electronics Work		

Subject: **Bid Release 3 - Supplement No.13**

Please be advised of the following supplemental information which is to be included in the Proposal as it pertains to the above referenced Bid Packages. This Supplement is issued to modify, explain and/or clarify the original Bid Documents.

General Instructions to All Bidders

- A. The Bid Proposal due date **Remains** Tuesday, **June 27, 2017 at 10:00 A.M. CST** at 100 Parkers Mill, Oswego IL – Oswego Village Hall for all trade contractors:

The last day for questions will be June 26, 2017.

Note: Bids are to be dropped off at the Oswego Village Hall. Bids will be opened at the Oswego Village Hall. 100 Parkers Mill, Oswego, IL.

- B. All Bidders are reminded that by submitting a bid, the bidder agrees to the content of the Bid Documents inclusive of Bid Forms, Insurance/Bonding Requirements, Safety Plan, etc. provided with the Bid Documents.
- C. Supplement 13 includes the following items:
1. Scope of Work Clarifications, Question/Answers.
- B. A 10% bid bond must be submitted with all bids and shall be made in favor of the Village of Oswego
- C. Read the entire supplement regardless of Bid Package referenced. Some items affect multiple Bid Packages and as such, those Trade Contractors shall be responsible for their scope of work affected.
- D. Read all bidder questions and answers attached to the end of this supplement regardless of Bid Package question is referenced under. Some answers affect multiple Bid Packages and as such, those Trade Contractors shall be responsible for their scope of work affected by these questions and answers. Incorporate all these responses that pertain to your trade scope of work.
- E. All Trades shall provide all LEED Requirements and Documentation pertaining to each trades scope of work. This is a LEED Silver Project.

All other terms and conditions of the Bid Documents remain the same.

Proposal Form Acknowledge receipt of this Supplement No. 13 in your Proposal Form.

Sincerely,
GILBANE BUILDING COMPANY

Stephanie A. Mueller
Chief Purchasing Agent

Question:

Architect Response:

Gilbane Response:

1	Page 5 2.1-A-5 specifies a Milestone M50 recorder (no substitutions) Page 7 2.6-A provides a spec for a recorder These are not anywhere alike. The M50 is an i7 processor and a standalone unit. The spec is for a Xeon processor unit in a SAS configuration. Completely different.	The Milestone M50 NVR should be utilized with no substitutions, disregard page 7 part 2.6A. Also please add a motion factor of 50% to the recording requirements.	
2	The M50 is an "off the shelf" unit with available pricing. The recorder on page 7 is a custom built and priced unit, usually from a 3 rd party and pricing may take a little time. In either case, I cannot price because I do not see any video recording capacity requested. Please clarify.	Recording requirements: 24/7 motion based recording with audio recording in the holding area and interview rooms. 7 frames per second, 30 days of storage retention.	