

January 23, 2015

Addendum to: HVAC Replacement

The Village of Oswego Police Department recently published a Request for Proposal (RFP) to replace the HVAC System. The scope of the project has changed and therefore we are rebidding the project. Those who attended our previous location viewing and signed in at the desk are welcome to attend but not required to attend this RFP viewing meeting. Any vendor who is interested in submitting a bid for this project who DID NOT attend our last viewing meeting must attend a mandatory location viewing which took place at the Oswego Police Department, Friday January 23, 2015 at 9a.m.

During this viewing two questions were raised that needed clarification. The response to these questions are listed below:

1. Refer to Page 5 of the RFP (Building Air Conditioning Unit): The third bullet point down says, "Furnish and install a new 30 ton condensing unit and cooling coil with a minimum EER of 10.8 based on consortium for energy Efficiency (CEE) requirements".

Correction: The unit should be a 20 ton condensing unit

2. Refer to Page 5 (Server Room Air Conditioning Unit): The second bullet point down says, "Furnish and install a 2 ton condensing unit on the East side of the building on a new equipment pad".

Correction: The equipment pad should be a concrete pad