



REQUESTS FOR BIDS

Monument Sign & Site Directional Signage

ADDENDUM #1

August 3, 2018

Acknowledge Receipt of Addendum #1

(Signature)

(Company)

(Date)

Addendum #1

Monument Sign & Site Directional Signage

August 3, 2018

Addendum #1 is hereby released to the changes listed below.

1. Clarify how the sign is to be lit.

Answer: Provide internal lighting to back light the letters, like the drawing below.



2. Clarify what size letters are to be used?

Answer: The tallest letter on the top row is 12”.

The tallest letter on the bottom row is 8”.

3. Clarify type of letters are to be used? This

Answer: The letters are to be laser cut in the metal panel in lieu of surface mounted letters. Provide Lexan or translucent glass at laser cut openings.

Note: This is a revision from the original Attachment A.

5. Provide specifics on aluminum medallions. Final drawings will be provided when the contract is awarded.



6. Will the landscaping be completed before the monument sign is installed?

Answer: The landscaping will not be installed before the monument sign.

7. Can the soils be disposed of onsite?

Answer: The spoils will need to be removed and disposed of legally offsite.

8. When will the asphalt binder course be installed?

Answer: The binder course is schedule to be installed no later than 8/22/18.

9. Change: Please use the revised Bid Sheet Document which is attached.

10. Clarification: Contractors will be able to use any of the following owner supplied items which are located on the west side of the property to complete this project. If you need to make additional visits to the site, you must check in at the construction trailer, and wear the appropriate PPE.

Brick (1890) total. Brick dimensions: 11-3/4”L x 2-1/4”W x 3-1/2”D

Stone Cap (4) total. Dimensions: 45”L x 45”W x 4”D

Stone Panels (10) total. Dimensions: 47”L x 35-3/4”W x 2-1/4”D

Stone Panels (1) total. Dimensions: 53”L x 24”W x 2-1/4”D

Stone Panels (1) total. Dimensions: 47-1/2”L x 23-3/4”W x 2-1/4”D

Stone Panels (2) total. Dimensions: 41-1/4” x 35-3/4” x 2-1/4”D

Cinder Block (61) total.

11. Change: A revised bid sheet has been included.

End of Addendum