



REQUEST FOR PROPOSAL FIRE HYDRANT
PAINTING SERVICES– ADDENDUM
MAY 14, 2020

1. IMPORTANT INSTRUCTIONS TO RESPONDENTS

This addendum must be read, signed and dated by the respondent and included with the proposal documents submitted by the respondent on or before the proposal due date and time. Failure to include this addendum with the proposal documents may result in an rejection. The respondent will carefully note the inclusion of this addendum on the bid form.

2. QUESTIONS/CLARIFICATIONS:

1. Are there drawings for this job or specs.
No, basic fire hydrant.
2. Do we need a bid bond to participate?
No.
3. To confirm, the painting is for roughly 250 units per year?
Yes, estimated 250 per year.
4. Are there any expanded procedures to follow regarding cleaning up of the sandblasting / removal of paint beyond what is outlined in SSPC-SP6?
Refer to section C. Commercial Blasting Requirements in the Request for Proposal. No other requirements above what is outlined in this document are required.
5. There are numbered tags on each of the hydrants; before the sandblasting process will those be removed?
Yes, the numbered tags and chains will be removed.
6. Do you need my company information to be on file with the Village of Oswego so we can get any addendums sent out and be on the list for any other ones going forward. We have signed up through the DemandStar platform as well and will familiarize ourselves with that process, so we make sure that we submit everything in time.
No, as long as you are registered with DemandStar you will receive our notifications.

3. ACKNOWLEDGMENT

The Respondent acknowledges receipt of this Addendum and understands its content to the Proposal Documents.

Authorized Signature

Date