



1135 South Lake Street • Montgomery, Illinois 60538  
Engineering Inquiries (630) 301-6882  
Inspections (630) 301-6811 • FAX (630) 897-6094

May 13, 2019

Jennifer Hughes, P.E.  
Village of Oswego Public Works Director  
100 Parkers Mill  
Oswego, Il 60543

Reference: Stonehill Road Lift Station Decommission and Sanitary Sewer Extension-Oswego, Il.

Dear Ms. Hughes,

The plans submitted for review have been approved by our engineering staff and is hereby approved. The improvements need to be installed in accordance with the most current plans.

1. Due to the fact that the IEPA (Division of Wastewater Pollution Control) has **not** issued their permit, construction of the proposed public sewer may not yet begin.
2. The contractor shall provide a 48-hour start notice to our Engineering Department at (630) 301-6805 prior to starting construction of the public sanitary sewer. If this contractor has not yet been selected, it will be the responsibility of the Village of Oswego or HR Green, Inc. to forward this letter to the contractor who will install the proposed public sewers.
3. So as to prevent any infiltration, inflow, or debris from entering the public sewer, a plug will need to be installed in the existing manhole, as shown on the plans. This plug is to be removed only upon approval by the Village or the District, and only after any accumulated water and/or debris has been properly removed. Under no circumstances are overland flows or trench drainage allowed to enter into any sanitary sewer.
4. Please pay the televising fee in the amount of \$271.18 (See attached invoice). Televising of the new public sewer can only be scheduled upon verification that our televising trucks have clear access routes to all sanitary structures.
5. Within sixty (60) days of the completion of our telefinish letter, one complete signed & sealed copy of sanitary record drawings will need to be emailed to the District in PDF format.

If there are any questions regarding any of the above material, please contact us for clarification.

Sincerely,  
Fox Metro Water Reclamation District

A handwritten signature in black ink, appearing to read "Michael L. Frankino", with a long horizontal flourish extending to the right.

Michael L. Frankino  
Assistant Engineering Supervisor

C: Jim Burbridge - Village of Oswego Community Development  
Tim Zasada - Village of Oswego - Assistant Public Works Director  
David Schultz - HR Green, Inc.  
Project file