

Addendum to: HVAC Replacement

- Your RFP must provide the following information:
 1. Manufacturer/Brand Name of the Boiler, Air Conditioning Units, Water Heater (All must be commercial grade)
 2. Specifications and Sizes of the Boiler, Air Conditioning Units, Water Heater

- Your installation shall include the replacement of all associated piping, drains, couplings, mounting hardware, curbs and structural supports.
- The VAV box in the records room must be replaced.
- The Energy Efficient Equipment Technical Specifications page of the grant states the following:

Scope of Project: Provide energy efficient equipment and controls to meet the requirements of the Illinois Department of Commerce and Economic Opportunities Illinois Energy Now (IEN) incentive program, as defined below:

3. *HVAC Controls Upgrade*
 - a. *Provide all labor and materials required to remove existing pneumatic HVAC control system and replace with a Direct Digital Control (DDC) Building Management System.*

***During the mandatory meeting the question was asked about replacing the pneumatic thermostat controls throughout the building. Those pneumatic thermostat controls must be replaced. Currently there are 11 in the building.