



INVITATION TO BID
BOOSTER STATION GENERATOR PROJECT
26-6070-02
ADDENDUM NO. 1
March 12, 2026

1. IMPORTANT INSTRUCTIONS TO BIDDERS

This addendum must be read, signed, and dated by the firm and included with the documents submitted by the firm on or before proposal closing date and time. Failure to include this addendum with the documents may result in the rejection of the proposal.

2. ATTACHMENTS TO THIS ADDENDUM:

3. QUESTIONS:

Q: What type of conduit should be used inside the booster stations.

A: Use rigid steel.

4. CLARIFICATIONS

- None

5. ACKNOWLEDGMENT

The firm acknowledges receipt of this Addendum and understands its content to the Request for Proposal Documents.

6. SIGNATURE AND DATE

Authorized Signature

Date